



SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

An ISO - 9001:2008 Certified Institute

TEST CERTIFICATE

000267494

Issued to :

VISAKA INDUSTRIES LIMITED
VISAKA TOWERS
1-8-303/69/3
S.P. ROAD
SECUNDERABAD - 500003,AP

Kind Attn: MR JAWAHAR RAWTANI , -

Sample Particulars:

One sample described as Fibre Cement flat sheet, Brand name- V board, was received.


J.O.No. 212-141-2276
Reg.No. 1339093
Date 28-01-2013
GC-01 (REV-04)
Your Ref.No. PO NO 10093
Date 24.11.2012

“ The sampling was not carried out by Shriram Institute for Industrial Research. The sample details provided in the test certificate are based on declaration by the party”

TEST RESULTS

<u>S.No.</u>	<u>Tests</u>	<u>Results</u>	<u>Protocol adopted</u>
1.	Free Moisture Content % by mass	6	As per guidelines of IS 2380 pt-3 - 1977

DOR: 24.12.2012
DOC: 28.01.2013


AUTHORISED SIGNATORY
(EMPLOYEE CODE: 6094)