



# SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

An ISO - 9001:2008 Certified Institute

## TEST CERTIFICATE

000267498

**Issued to :**

VISAKA INDUSTRIES LIMITED  
VISAKA TOWERS  
1-8-303/69/3  
S.P. ROAD  
SECUNDERABAD - 500003,AP

Kind Attn: MR JAWAHAR RAWTANI

**Sample Particulars:**

One sample described as Fibre Cement flat sheet, Brand name- V board, was received.

J.O.No. 212-141-2280  
Reg.No. 1339093  
Date 28-01-2013  
GC-01 (REV-04)  
Your Ref.No. PO NO 10093  
Date 24.11.2012

“ The sampling was not carried out by Shriram Institute for Industrial Research. The sample details provided in the test certificate are based on declaration by the party”

### TEST RESULTS

<u>S.No.</u>	<u>Tests</u>	<u>Results</u>	<u>Protocol adopted</u>
1.	Tensile Strength, MPa, (parallel to the plane)	6.0	As per guidelines of IS 2380 pt-6 - 1977

\*\*\*\*\*

DOR: 24.12.2012  
DOC: 28.01.2013

AUTHORISED SIGNATORY  
(EMPLOYEE CODE: 6094)